

# BRE Global

Notified Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com) Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of constancy of performance,

**0832-CPR-S0029**

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9<sup>th</sup> March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **Model B, D & E Wet Alarm Valves for use in Automatic Sprinkler Installations**

*(For full product details and conditions of use refer to appendix)*

Produced by or for

#### **Rapidrop Global Limited**

**Rutland Business Park, Newark Road  
Peterborough PE1 5WA  
United Kingdom**

and produced in the manufacturing plant(s)

**SS0008**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 12259-2:1999 +A1:2001 +A2:2005**

under system 1 are applied and that

***the products fulfil all the prescribed requirements set out above.***

This certificate was first issued on 17 April 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



S A Colwell, Business Group Manager, Fire Suppression  
On behalf of BRE Global Limited  
Date of issue: 17 April 2015  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).

## Appendix to Certificate of constancy of performance 0832-CPR-S0029

The Wet Alarm Valve Models B, D & E with and without Model E Retard Chamber covered by this Certificate of Conformity placed on the market by Rapidrop Global Limited; are identified below and must be installed in accordance with the manufacturers installation instructions:

Product Name	Description	Nominal Size mm	Maximum Working Pressure	Orientation
Wet Alarm Valve	Model B	80, 100, 150, 200	12 bar	Vertical only
Wet Alarm Valve	Model D	100, 150, 200	12 bar	Vertical only
Wet Alarm Valve	Model E	100, 150	12 bar	Vertical only



S A Colwell, Business Group Manager, Fire Suppression  
On behalf of BRE Global Limited  
Date of issue: 17 April 2015  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).