

## Sprinkler System Alarm Testers

Each separate sprinkler system must be equipped with a separate waterflow alarm. In a high rise building, the system for each floor must be separately alarmed. Where pressure reducing valves are used, a dual alarm and drain piping arrangement is required. The alarm testers listed below combine test and drain valves, a waterflow sight glass, and a calibrated flow orifice in a single assembly to simplify the piping required for such arrangements.

### Model TDV

Model TDV. Sprinkler System Alarm Tester. 1 and 1-1/4 in. NPT female threaded inlet with male threaded outlet. 1/2 in. nominal orifice. 175 psi (1205 kPa) rated working pressure.

<b>Company Name:</b>	Rapidrop Global Limited
<b>Company Address:</b>	Rutland Business Park, Newark Rd, Peterborough PE15WA, United Kingdom
<b>Company Website:</b>	<a href="http://www.rapidrop.com">http://www.rapidrop.com</a>
<b>New/Updated Product Listing:</b>	No
<b>Listing Country:</b>	United Kingdom
<b>Certification Type:</b>	FM Approved