



Valves | Water Control Valves (OS&Y and NRS Gate Valves) | **Gate Valves, Outside Screw and Yoke**

Fig 133FF, Fig 133GG, Fig 133JJ, Fig 133FG and Fig 133FJ

Resilient Seated Gate Valves. Available with the following end connections and rated working pressures:

Product Specification

Model No	Valve Size		Rated Working Pressure		End Connection
	in	(mm)	psi	(kPa)	
Fig. 133FF	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Flange × Flange
Fig. 133FF	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12, 14, 16, 18	(50, 65, 80, 100, 125, 150, 200, 250, 300, 350, 400, 450)	250	(1720)	Flange × Flange
Fig. 133FF	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12, 20, 24	(50, 65, 80, 100, 125, 150, 200, 250, 300, 500, 600)	200	(1375)	Flange × Flange



Model No	Valve Size		Rated Working Pressure		End Connection
	in	(mm)	psi	(kPa)	
Fig. 133GG	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Groove x Groove
Fig. 133Jj	3, 4, 6, 8, 10, 12	(80, 100, 150, 200, 250, 300)	300	(2065)	Mechanical Joint x Mechanical Joint
Fig. 133FG	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Flange x Groove
Fig. 133Fj	3, 4, 6, 8, 10, 12	(N/A, 100, 150, 200, 250, 300)	300	(2065)	Flange x Mechanical Joint

Details

Class of Work : 1120 - OS&Y and NRS Gate Valves

Approval Standard : FM 1120, 1130 - Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)

Certification Type : FM Approved

Listing Country : United Kingdom

Category : Gate Valves, Outside Screw and Yoke

Company

Rapidrop Global Limited

Rutland Business Park, Newark Rd, Peterborough
PE1 5WA, United Kingdom
United Kingdom

<http://www.rapidrop.com>