



Sprinkler System Components | Branch Line Alarm Testers | **Sprinkler System Alarm Testers**

Models 802-025, 802-032, 802-040, 802-050

Product Description

Product Specification

Model No	Nominal Pipe Size		K-Factor	Rated Working Pressure		Remarks
	in	(mm)		psi	(kPa)	
802-025	1	(25)	2.8, 4.2, 5.6, 8.0	300	(2065)	a
802-032	1 1/4	(32)	2.8, 4.2, 5.6, 8.0	300	(2065)	a
802-040	1 1/2	(40)	2.8, 4.2, 5.6, 8.0	300	(2065)	a
802-050	2	(50)	2.8, 4.2, 5.6, 8.0	300	(2065)	a

Remarks:

a. Devices supplied with female NPT or female BSPT end connections.

Details

Category	Sprinkler System Alarm Testers
Class of Work	1625 - Branch Line Testers
Approval Standard	FM 1625 - Sprinkler System Alarm Test Devices
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Rapidrop Global Limited
 Rutland Business Park, Newark
 Rd, Peterborough PE1 5WA,
 United Kingdom
 United Kingdom
<http://www.rapidrop.com>