

## Data Sheet 1.57 Issue E











# Grooved Swing Check Valve Fig. 301

#### **General Description**

Rapidrop Figure 301 is a rubber faced, grooved swing type check valve that allows water flow in one direction only. A hinged clapper remains open with water flowing in one direction, and automatically closes, with the help of an incorporated spring, when flow stops preventing backflow.

Rapidrop Figure 301 check valve features two drain plugs, one positioned before and one after the clapper to facilitate efficient maintenance and drainage. Additionally, it includes two auxiliary plugs, also located before and after the clapper, allowing for easy integration of auxiliary equipment.



Groove to ISO 6182



17.2 bar (250 psi) FM Approved 20.7 bar (300 psi) UL Listed 25.0 bar (362 psi) VdS, LPCB & CNBOP Certificates

#### Temperature Range

0°C - 80°C (32°F - 176°F)

#### Coating


Fusion Bonded Epoxy Coating

In accordance with ANSI / AWWA C550 or painting upon request


#### **Approvals**

FM Approved, UL Listed, LPCB, VdS and CNBOP Certificates

#### **Dimensions**









Rapidrop Global Ltd
T: +44 (0) 1733 847 510 F: +44 (0) 1733 553 958
e: rapidrop@rapidrop.com
w: www.rapidrop.com



## Data Sheet 1.57 Issue E












## Grooved Swing Check Valve Fig. 301



#### Installation

The valve must be installed with the direction arrow on the body coincident with the direction of the flow in the pipeline. Rapidrop grooved swing check valve can be installed horizontally or vertically. For vertical pipework the flow direction should be upwards only. Large valves are provided with lifting eye bolt, which should be used to manoeuvre the valve.

**Note:** Check valves can be compromised by excessively turbulent water flow, which can lead to product damage. To minimize this risk, it's important to install check valves at a sufficient distance from sources of turbulence such as pumps, elbows, tee's, expanders, reducers, or similar components. Best practices in piping recommend placing the valve at least five times the pipe's diameter away from these components.

#### Material Specification

No	Description	Material
1	Valve Body	Ductile Iron 65-45-12
2	Spring	Stainless Steel 304
3	Hinge Pin	Stainless Steel 420
4	Hinge Bushing	Brass C26800
5	Hinge Plug	Malleable Iron Zinc Plated
6	Clapper Arm	Stainless Steel 304(≤4") Ductile Iron 65-45-12 (>4")
7	Clapper Gasket	EPDM
8	Retaining Disc	Stainless Steel 304
9	Spring Washer	Stainless Steel 304
10	Nut	Stainless Steel 304
11	Seat Ring	Brass C83600
12	Drain Plug	Malleable Iron Zinc Plated
13	Eye Bolt*	Carbon Steel Zinc Plated

<sup>\*</sup>DN200 / 8" and above

#### Important Installation Information

- Rapidrop Figure 301 grooved swing check valve must only be installed by a competent person in accordance with requirements of the local authority having jurisdiction. Deviations from these standards will invalidate warranty.
- It is the responsibility of the installing contractor to include a copy of this document in the sprinkler system installation, operating and maintenance manual.
- Alterations to Rapidrop products will void any warranty.
- Figure 301 grooved swing check valve should be inspected and maintained during routine sprinkler system inspections by a competent person in accordance with national codes/requirements.
- Failure to follow these instructions could cause improper operation, resulting in personal injury and/or property damage.
- For further details and technical support please contact your Rapidrop sales representative.

DS: 1.57 Issue E 02/09/2024 © 2024 Rapidrop

Rapidrop Global Ltd
T: +44 (0) 1733 847 510 F: +44 (0) 1733 553 958
e: rapidrop@rapidrop.com
w: www.rapidrop.com